

Ei3018 - Carbon Monoxide



Always ensure that the green mains LED indicator is constantly illuminated. If this LED goes out you must ring an electrician.



Test your alarm regularly by pressing the test button in the centre of the alarm, the green LED will flash rapidly, ensure all other interconnected alarms sound.



In the event of a CO (Carbon Monoxide) activation the Red LED will flash rapidly call a gas-safe engineer and evacuate the property.



You can silence a nuisance alarm by pressing the test button on the alarm with the rapidly flashing red LED. You cannot silence a high-level CO activation.



The alarm will commence a self-test every 40 seconds, the green LED will flash once.



If the alarm is emitting a single/series of beeps in conjunction with an amber flash, call an electrician.